

Type test Certificate of complete type tests

KEC International Limited

Vadodara, Gujarat, India

have successfully passed the type test sequence on a

cable system (220 kV)

Cable: 1 x 2000 mm² – Cu – XLPE insulated
Manufacturer: KEC International Limited (Cable Division)

Outdoor termination: OHVT-245P, OHVT-245C
Manufacturer: Raychem RPG (P) Ltd.

Cable connection: PHVS-245
Manufacturer: Raychem RPG (P) Ltd.

Joint: EHVS-245
Manufacturer: Raychem RPG (P) Ltd.

The test object passed the required clauses of


IEC 62067

The test results are recorded in Certificate No.


TIC 1013-15

This Certificate is issued on 2 March 2015

KEMA Nederland B.V.



S.A.M. Verhoeven
Director Testing, Inspections & Certification The Netherlands



Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.